



Water Utility Monthly Report- October 2016



Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec	Total
Total Finished Water MG 2016	67.42	63.58	71.17	67.79	71.98	77.78	80.27	82.00	73.84	71.40	0.00	0.00	727.23
Total Finished Water MG 2015	72.78	66.79	75.27	70.43	77.95	78.63	78.24	84.08	82.52	78.54	66.25	66.50	897.98
Variation 2016 vs 2015	5.36	3.21	4.10	2.64	5.97	0.85	2.03	2.08	8.68	7.14	0.00	0.00	170.75
2016 % of Capacity	40%	38%	42%	40%	43%	46%	48%	49%	44%	42%	0%	0%	40%
2015 % of Capacity	43%	40%	45%	42%	46%	47%	47%	50%	49%	47%	39%	40%	45%
Highest production day 2016	2.54	2.48	2.54	2.52	2.76	3.41	2.81	3.19	2.93	2.69			
Total completed work orders	145	273	239	388	192	287	451	257	226	246			2704

Monthly Highlight

Water is advertising for two new Apprentice positions to start after Jan 1, 2017.
 Heater unit at south plant had to be replaced.
 Annual work on Emergency Generators have been completed.
 Survey was conducted of the Meek Street Maintenance Facility to address questions posed by neighboring residents.



Water Utility Monthly Report- Oct 2016



Repair work orders completed:

827 N. Noble St- Service Repair of hot side valve

1500 N. State Road 9- Main Break repair- replaced failing clamp on main

406 Mount St- Leaking service line repair

615 Hill Crest- Leaking service tap- Removed old copper line bend, installed 90 bend and installed line to home

941 W. North St.- Installed two meter settings and taps for new duplex

287 E. 300 N.- Installed new hose bib assembly for Parks Department

Maintenance work completed:

804 S State St- Raised meter pit

918 Courtland Ct.- Inspected meter pit height for customer

CIP data collection- Wood st, Swope St., N. Spring st., Howard St, Baldwin, E North, Grant- 247 Meter pits inspected

Annual generator maintenance completed. North plant emergency generator and portable unit.

Service work orders completed:

New Meter pit installation inspections:

1627 Leisure Way 923 Bobtail Dr.

1614 Leisure Way 793 Prospectors Dr.

1357 Morningside Dr.

1627 Leisure Way

981 Blossom Ct



Water Utility Monthly Report- Oct 2016



Completed Distribution Crew Activities	Completed
Assist other Utilities	1
Check For leaks	6
Locate	6
Discolored Water	1
Grounds Maintenance	3
Hydrant Flushing (Annual)	23
Hydrant Flushing (Routine Water Quality)	32
Install New services	1
Low pressure	2
Main Break (Leaking services, or main repair)	1
Service Leak Repair	3
Map Correction requests (GIS) & locating	62
Meter pit inspection	15
Raise/lower settings	1
Repair/ Replace meter	0
Turn off	11
Turn on	4
Hydrant inspections	544
Valve Activity	6
Valve exercise	15
Valve inspection	0
Vehicle maintenance/repair	7
Buliding Maintenance	2

Completed Filtration Crew Activities	Completed
Grounds maintenance- Plants, Tower, Source	8
Distribution System Sampling	15
Well P.M.	7
Tower activity	0
Misc- Plant	2
Misc- Activity	1
Misc- Source	1
Vehicle Maintenance	7
Buliding material Condition	0
Sensor	1
pump maintenance	2