

Wastewater Utility 2019 Monthly Report



February 2019



Month	January	February	March	April	May	June	July	August	September	October	November	December	Total
Total MG Treated Effluent 2019	123.30	138.30	114.45	126.25	75.78	85.60	98.27	115.29	132.71	79.28	120.06	97.73	261.6
Total MG Treated Effluent 2018	91.20	125.71	114.45	126.25	75.78	85.60	98.27	115.29	132.71	79.28	120.06	97.73	1262.33
Total Monthly Precipitation 2019	2.24	6.52											8.76
2019 Monthly Percent Capacity	99%	123%											
Actual Design Flow 4.0 MGD													

- Sewer Crew Activities**
 - Sanitary Sewer Repairs
 - Lateral Repair At 1210 Bowman Drive
 - Cleaned 2100' Of Sewer In Waterview Estates
 - Cleaned Grease Trap Near St James North L.S.
 - New Laterals Inspected
 - 4
 - Catch Basin Repairs
 - Near Parking Lot Across From Boys & Girls Club
 - Storm Water Repairs
 - Clean Out Drain At Boots Ditch On Mckenzie Rd
 - Repair Storm Drain Erosion - 7th & Indiana
 - Repair Storm Drain & Replace Pipe To Main At 317 S. Noble
- Plant Crew Activities**
 - Sludge Pressed / Gallons
 - 768,100
 - Motors Repaired/Replaced
 - Replaced #4 RAS Pump
 - Replaced Paddle Drive Motor
 - Replaced VFD Drive And Roto Lock Motor
 - Repaired Screen Conveyor Shaft
 - Installed Electrical Recorders On Main Power, Checking For Power Spikes
 - Replaced Plant Water Motor
 - Replaced Sampler Pump Motor
 - Replaced Electrical Contractors On RAS Pumps
 - Replaced Electrical Contractors On RAS Pumps